

**COUNTY OF MONROE
DEPARTMENT OF TRANSPORTATION**

ADDENDUM NO. 2

TO THE
CONSTRUCTION SPECIFICATIONS AND RELATED DOCUMENTS

FOR

**EAST RIDGE ROAD REHABILITATION
CITY LINE TO CULVER ROAD**

Capital Improvement Project No.
PIN 4753.59

PREPARED BY

T.Y. Lin International
255 East Avenue
Rochester, New York 14604



TO ALL BIDDERS:

The following constitutes ADDENDUM NO. 2 of the Contract Documents. Each Bidder shall acknowledge receipt of this Addendum on Page P-5 of the Proposal.

Pages ADD 2-1 through ADD 2-2

April 25, 2012

**EAST RIDGE ROAD REHABILITATION
CITY LINE TO CULVER ROAD**

Capital Improvement Project No.
PIN 4753.59

To All Bidders:

Pages ADD 2-1 through ADD 2-2 constitute Addendum No. 2 to the Contract Documents. Make the following changes to the Contract Documents, Contract Specifications, and Related Documents:

Specifications and Related Documents:

2-1) **DELETE** Item 1-22 of Addendum No. 1 and **REPLACE** with the following:

On Sheet 9 of 160, the intent of the full depth saw cut shown on the Asphalt Edge Removal Detail is for the saw cut to extend through the existing asphalt section to the top of existing concrete. The intent is to not saw through the existing concrete pavement.

The 1' of existing asphalt that is to be removed adjacent to the existing concrete edge will be paid for under Item 203.02 – Unclassified Excavation and Disposal as indicated on the detail. Regardless of the manner in which the asphalt is removed the work will be paid for under Item 203.02.

2-2) In the contract plans, on Sheet 16 of 160, **ADD** the following note, Note No. 6, to the Nighttime Work Operations Notes:

6. Night work for intersections shall be done in the night work area (as shown on the plans) and shall include storm sewer work including installation of any storm water quality structures near the intersections, boxout of the intersections, conduit crossings at intersections, and all paving of the intersections.

Other construction activities such as installation of curbing, sidewalks, traffic signal equipment, pull boxes and other items needing to be installed in the intersections **may** be performed at night with approval from the engineer in charge and the Monroe County Department of Transportation, but will receive no additional compensation in doing so.

The bid opening date for this project shall remain the same.