Purchasing and Central Services

Monroe County, New York

Maggie Brooks
County Executive

Dawn C. Staub
Purchasing Manager

ADDENDUM NO: 1

BID PROJECT NO: 0904-12 MORRIS 24" NCD PUMP IMPELLER

DATE: September 5, 2012

BIDDERS PLEASE NOTE:

Bid date remains September 11, 2012 @11:00 AM
Replace pages 4 & 5 of the specifications with attached and include with your bid.
NOTE: changes to sections 1.01 and 3.01 j.

SIGN this Addendum below acknowledging receipt and understanding and either INSERT in document or RETURN under separate cover.

MONROE COUNTY

Greg Hart

Greg Hart Buyer
(585) 753-1135

The undersigned bidder acknowledges receipt and understanding of Addendum No. 1 to Bid Project No. 0904-12 MORRIS 24" NCD PUMP IMPELLER.

_____, 2011
Date

_____
Name of Company

_____
Authorized Signature

_____
Title

1.00 General:

1.01 Scope:

The Monroe County Department of Environmental Services, Division of Pure Waters, is seeking a qualified bidder to supply a Morris, 24" **RH (right hand)** NCD Pump Impeller. To be used on existing Morris NCD pump; serial number M 13800-3801.

1.02 Location:

County of Monroe
Irondequoit Bay Pump Station (IBPS)
1575 Lakeshore Blvd.
Rochester, New York 14617

1.03 Contact Person:

Steve Morse
Monroe County Department of Environmental Services
Frank E. VanLare Wastewater Treatment Facility (FEV)
1574 Lakeshore Boulevard
Rochester NY 14617
(585) 753-7682 – Office
e-mail: smorse@monroecounty.gov

1.04 Submittal:

All bidders must submit one (1) complete set of their specifications and drawings with the bid, for approval prior to the award.

2.00 Quality Assurance:

2.01 Applicable Codes and Standards:

The contractor shall comply with the following codes and standards:

a. OSHA - Occupational Safety & Health Act.

b. NIOSH - National Institute of Occupational Safety & Health.

c. ANSI - American National Standards Institute.

d. ASTM - American Society for Testing & Materials.

2.02 Standard Product:

All replacement material shall be new and unused. The part shall be Original Equipment Manufacturer, (OEM).

3.00 Equipment:

3.01 Impeller Information:

a.	Part No.:	5613909002.
b.	Manufacturer:	Morris.
c.	Type:	non clog 24" NCD pump impeller.
d.	Serial #:	Existing pump serial # M -13800- 3801.
e.	Impeller:	3V, diameter 42.250 inch.
f.	Material:	Cast Iron ASTM A48 Class 35.
g.	Impeller Casting:	Must be a smooth casting with no holes, pits or imperfections.
h.	Balance:	To ISO 1940, Grade G 6.3 with ANSI S2.19 4.0 mils or better.
i.	Nose Wear Ring:	Impeller shall come with a Stainless Steel AISI 420, BRN 400-500 nose wear ring.
j.	Impeller Rotation:	Shall be Right Handed. Check rotation. When looking down at the pump, at the coupling hub, impeller should spin clockwise.
k.	Impeller Balancing:	Impeller must be balanced with the nose ring on the impeller.
l.	Impeller Fit:	The successful bidder shall be responsible for any problems which occur with the impeller fit for a period of five (5) years from date of acceptance. This impeller is being purchased as a spare part and will be installed when needed.