



NOTES:

1. REMOVE EXISTING PAVEMENT AND PAVEMENT SUBBASE UNDER ITEM 203.02 M
2. SLOPE SHEETING & BRACING PER OSHA, SPECIFICATION. TRENCH SHIELD OR SHEETING TO BE LIFTED ABOVE THE SPRING LINE.
3. WHERE STORM SEWER CROSSES PREVIOUSLY INSTALLED SANITARY SEWER, WATER OR GAS MAIN, ETC. TRENCH SHALL BE EXCAVATED DOWN TO THE PREVIOUSLY LAID UTILITY AND BACKFILL WITH #2 CRUSHED STONE COMPACTED IN 150 mm LIFTS TO INSURE ADEQUATE SUPPORT.

## STORM SEWER TRENCH IN PAVED AREA

NOT TO SCALE

2/2/04

REVISED