



NOTES:

1. PUMPER CONNECTION SHALL FACE PAVEMENT.
2. IF REQUIRED OFFSETS WILL BE USED TO SET HYDRANT AT PROPER ELEVATION.
3. HYDRANT WEEP HOLES SHALL BE PLUGGED AND STONE DRAIN OMITTED A.D.B.E. WHEN GROUND WATER IS ENCOUNTERED IN THE TRENCH.

HYDRANT RELOCATION

ITEM 660.14 M

NOT TO SCALE

4/1/98

REVISED