



NOTES:

1. THE VOLUME OF THE NEW WATERMAIN SHALL BE DEDUCTED WHEN CALCULATING THE VOLUME OF SAND BACKFILL. COVER OVER NEW WATERMAINS SHALL BE 1.5 m MINIMUM FROM PROPOSED FINISH GRADE.
2. SEE TRENCH EXCAVATION AND BACKFILL FOR ADDITIONAL NOTES, MATERIALS, PAY LIMITS AND DETAILS.

WATERMAIN BEDDING
NOT TO SCALE

2/2/04

REVISED