



NOTES:

1. FRAMES SHALL BE DUCTILE IRON PER ASTM A526 GRADE 70-50-05. FRAME AND GRATES SHALL MEET H-20 LOADING REQUIREMENTS.
2. DRAIN BASIN TO BE CUSTOM MANUFACTURED ACCORDING TO PLAN DETAILS. SEE DRAINAGE TABLES FOR STRUCTURE HEIGHTS.
3. DRAINAGE CONNECTION STUB JOINT TIGHTNESS SHALL CONFORM TO ASTM D3212 FOR CORRUGATED SCIPP (ADS N-12/HANCOR DUAL WALL), N-12 HP, & PVC SEWER (4"-24")
4. EXCAVATION TO INSTALL DRAIN BASIN TO BE PAID FOR UNDER ITEM 206.0201.
5. BASINS TO BE "ADS NYLOPLAST DRAIN BASINS" OR APPROVED EQUAL

STAND PIPE DRAINAGE INLET DETAIL

NOT TO SCALE - REVISED: 08/25/25