



NOTES:

1. CONTRACTOR SHALL USE INDUSTRIAL VACUUM SYSTEM WITH WATER JET TO EXPOSE AND LOCATE UTILITY.
2. CONTRACTOR SHALL BACKFILL WITH CONTROLLED DENSITY FILL ("FLOWABLE FILL") IN ACCORDANCE WITH NYSDOT STANDARD SPECIFICATION 204.01 CONTROLLED LOW STRENGTH MATERIAL TO WITHIN 3 1/2" OF THE SURFACE, THEN FINISH WITH 2" ASPHALT CONC. 19mm BINDER COURSE AND 1 1/2" ASPHALT CONC. 9.5mm TOP COURSE.

UTILITY WINDOW & RESTORATION

NOT TO SCALE - REVISED: 3/17/2025