



NOTES:

1. THE VOLUME OF THE NEW WATERMAIN SHALL BE DEDUCTED WHEN CALCULATING THE VOLUME OF SAND BACKFILL. COVER OVER NEW WATERMAINS SHALL BE 5' MINIMUM FROM PROPOSED FINISH GRADE.
2. SEE TRENCH EXCAVATION AND BACKFILL FOR ADDITIONAL NOTES, MATERIALS, PAY LIMITS AND DETAILS.

WATERMAIN BEDDING
NOT TO SCALE

3/1/06

REVISED