



39 West Main Street  
Rochester, NY 14614  
landbankcorp@monroecounty.gov

---

**Questions Related to Monroe County Land Bank RFQ – Asbestos Survey Services**

**Received as of April 10, 2026**

**Q: The current condition of the structure is vacant and dilapidated, is it safe to access?**

**A:** MCLBC has released a Structural Stability Assessment RFQ. The results of the assessment will be shared with the selected firm to help determine safe access conditions.

**Q: Analysis is required for PLM, depending on the material it would also need to be analyzed for TEM. Can this be included in the proposal as well?**

**A:** Yes, please include the TEM analysis cost should this be needed.